

CITY OF MASCOUTAH
3 WEST MAIN
MASCOUTAH ILLINOIS 62258

STREET LIGHTS, POLES AND ACCESSORIES
BID SPECIFICATIONS

BIDS DUE: APRIL 15, 2020, 2:00PM

**Submit full bid specifications with this bid sheet.*

Invitation for Bids – Street Lights, Poles and Accessories

The City of Mascoutah is seeking bids to furnish and deliver street lights, poles and accessories to the City of Mascoutah Electric Department. Bid specification packets may be obtained from the City Clerk's office at City Hall or downloaded at www.mascoutah.org. Sealed bids will be accepted at the office of City Clerk, City of Mascoutah, 3 West Main Street, Mascoutah, IL 62258 until 2:00 p.m., April 15, 2020.

BID SPECIFICATIONS

- QTY. 6 – Mid-block Assemblies consisting of Holophane Sitelink Pole with accessories, Camden Arm, Esplanade Luminaire set to IDOT Standards, reference number RFD237183. See attached Quote #: 2377-17-10162-8. No Substitutions.
- QTY. 3 – Southwest Corner Assemblies consisting of Holophane Sitelink Pole with accessories, 2 Camden Arms, 2 Esplanade Luminaires set to IDOT Standards, reference number RFD237184. See attached Quote #: 2377-17-10162-8. No Substitutions.
- QTY. 3 – Southeast Corner Assemblies consisting of Holophane Sitelink Pole with accessories, 2 Camden Arms, 2 Esplanade Luminaires set to IDOT Standards, reference number RFD237189. See attached Quote #: 2377-17-10162-8. No Substitutions.
- QTY. 1 – Spare Assembly consisting of 1 Holophane Sitelink Pole with accessories, 2 Camden Arms, 2 Esplanade Luminaires, and 2 fitters, reference number RFD313351 and RFD 313425. See attached Quote #: 2377-17-10162-8. No Substitutions.

Regardless of the estimated delivery date for the materials listed above, anchor bolts and templates for the materials listed above shall be shipped to the City of Mascoutah Electric Department immediately upon placement of the order for the materials listed above.

**Submit full bid specifications with this bid sheet.*

BIDDER INFORMATION
CITY OF MASCOUTAH

STREET LIGHTS, POLES AND ACCESSORIES

BID DATE: 2:00 PM, APRIL 15, 2020

BIDDERS NAME: _____

ADDRESS: _____

CITY, STATE: _____

PHONE: _____

QTY. 6 – Mid-block Assemblies consisting of Holophane Sitelink Pole with accessories, Camden Arm, Esplanade Luminaire set to IDOT Standards, reference number RFD237183. No Substitutions. **BID AMOUNT:** _____

QTY. 3 – Southwest Corner Assemblies consisting of Holophane Sitelink Pole with accessories, 2 Camden Arms, 2 Esplanade Luminaires set to IDOT Standards, reference number RFD237184. No Substitutions. **BID AMOUNT:** _____

QTY. 3 – Southeast Corner Assemblies consisting of Holophane Sitelink Pole with accessories, 2 Camden Arms, 2 Esplanade Luminaires set to IDOT Standards, reference number RFD237189. No Substitutions. **BID AMOUNT:** _____

QTY. 1 – Spare Assembly consisting of 1 Holophane Sitelink Pole with accessories, 2 Camden Arms, 2 Esplanade Luminaires and 2 fitters, reference number RFD313351 and RFD313425. No Substitutions. **BID AMOUNT:** _____

TOTAL BID AMOUNT: _____

WARRANTY: _____

ESTIMATED DELIVERY DATE: _____

By: _____ **Title:** _____

**Submit full bid specifications with this bid sheet.*



Quoted To: Authorized Holophane Distributor

Job Name: Mascoutah Streetscape
 Quote #: 2377-17-10162-8
 Quote Label: AHD

Quoted By: Michael Cortese
 618-779-8754
 Michael.Cortese@AcuityBrands.com

Job Location: Illinois
 Issue Date: 4/1/2020
 Bid Date: 6/30/2017

Type	Qty	Catalog #	Unit \$	Ext \$
		MID BLOCK ASSEMBLY		
	6	SLA30L8GSBP01BK(2)RXXXY-MOD SLCAM48/1BOL68BK H28CACSBKH TCOLLARASSYL8GBK (2)FGIUS SLGAGMKIT FPH AB RFD237183 *** NOTES: - 1/24/19 ADDED "FPH" - DUE TO THE HEIGHT OF THE CLAMSHELL BASE AND TRANSITION COLLAR THE APPROX. HT OF THE BOTTOM RECEPTACLE WILL NEED TO BE AROUND 60"-65". APPROVAL DWG WILL VALIDATE SITELINK ALUMINUM POLE, 30' TALL, "L8G" FLUTED SHAFT WITH A PLAIN POLE CAP, (2) RECEPTACLE PROVISIONS, WIREWAY DRILLING, SHOEBASE. HOLOPHANE BLACK SITELINK CAMDEN ARM, 48" LONG FOR A SINGLE FIXTURE, BOLT-ON WITH TRACNUTS INCLUDED. HOLOPHANE BLACK HAMILTON CAST ALUMINUM CLAMSHELL BASE, 28" DIAMETER. HOLOPHANE BLACK SITELINK TRANSITION COLLAR TO TRANSITION FROM THE POLE SHAFT TO THE CLAMSHELL BASE. HOLOPHANE BLACK GFI RECEPTACLE WITH SMALL IN-USE WEATHERPROOF COVER HOLOPHANE BLACK GASKET AND GROMMET KIT FOR ELECTRICAL WIREWAY SITELINK FLAGPOLE HOLDER FOR 1" POLE, TRACNUTS INCL. HOLOPHANE BLACK 1.25"X42" ANCHOR BOLTS INCLUDED		
	6	ESL2 P35S 40K AS BK TG 3 S BHDF13 200 BK Esplanade Tear Drop Teardrop LED 2 Series (ESL2): ESL2, 14,900 lumens; 3 COBs, 4000K CCT, Auto-sensing voltage (120 thru 277) 50/60 HZ, Black, Teardrop glass and door, Type 3 Asymmetric Distribution, Quick Lock Stem mount, Boston Harbor Decorative Arm Fitter, Slips Fits 2.00 Nominal Pipe (2.38") OD, Black		



Job Name: Mascoutah Streetscape
 Quote #: 2377-17-10162-8
 Quote Label: AHD

Quoted By: Michael Cortese
 618-779-8754
 Michael.Cortese@AcuityBrands.com

Job Location: Illinois
 Issue Date: 4/1/2020
 Bid Date: 6/30/2017

Type	Qty	Catalog #	Unit \$	Ext \$
------	-----	-----------	---------	--------

SOUTHWEST CORNER ASSEMBLY

- | | | | | |
|---|--|--|--|--|
| 3 | | SLA30L8GSBP01BK(2)RXXXY-MOD (2)SLCAM48/1BOL68BK H28CACSBK TCOLLARASSYL8GBK (2) FGIUS (2)SLGAGMKIT (2)FPH AB RFD237184 | | |
| | | *** NOTES:
- 1/24/19 ADDED "FPH"
- DUE TO THE HEIGHT OF THE CLAMSHELL BASE AND TRANSITION COLLAR THE APPROX. HT OF THE BOTTOM RECEPTACLE WILL NEED TO BE AROUND 60"-65". APPROVAL DWG WILL VALIDATE

SITELINK ALUMINUM POLE, 30' TALL, "L8G" FLUTED SHAFT WITH A PLAIN POLE CAP, (2) RECEPTACLE PROVISIONS, (2)WIREWAY DRILLINGS, SHOEBASE. HOLOPHANE BLACK

SITELINK CAMDEN ARM, 48" LONG FOR A SINGLE FIXTURE, BOLT-ON WITH TRACNUTS INCLUDED. HOLOPHANE BLACK

HAMILTON CAST ALUMINUM CLAMSHELL BASE, 28" DIAMETER. HOLOPHANE BLACK

SITELINK TRANSITION COLLAR TO TRANSITION FROM THE POLE SHAFT TO THE CLAMSHELL BASE. HOLOPHANE BLACK

GFI RECEPTACLE WITH SMALL IN-USE WEATHERPROOF COVER HOLOPHANE BLACK

GASKET AND GROMMET KIT FOR ELECTRICAL WIREWAY

SITELINK FLAGPOLE HOLDER FOR 1" POLE, TRACNUTS INCL. HOLOPHANE BLACK

1.25"X42" ANCHOR BOLTS INCLUDED | | |
| 6 | | ESL2 P35S 40K AS BK TG 3 S AO BHDF13 200 BK | | |
| | | Esplanade Tear Drop Teardrop LED 2 Series (ESL2): ESL2, 14,900 lumens; 3 COBs, 4000K CCT, Auto-sensing voltage (120 thru 277) 50/60 HZ, Black, Teardrop glass and door, Type 3 Asymmetric Distribution, Quick Lock Stem mount, Field Adjustable Output, Boston Harbor Decorative Arm Fitter, Slips Fits 2.00 Nominal Pipe (2.38") OD, Black | | |



Job Name: Mascoutah Streetscape
 Quote #: 2377-17-10162-8
 Quote Label: AHD

Quoted By: Michael Cortese
 618-779-8754
 Michael.Cortese@AcuityBrands.com

Job Location: Illinois
 Issue Date: 4/1/2020
 Bid Date: 6/30/2017

Type	Qty	Catalog #	Unit \$	Ext \$
------	-----	-----------	---------	--------

SOUTHEAST CORNER ASSEMBLY				
	3	SLA30L8GSBP01BK(2)RXXXY-MOD (2)SLCAM48/1BOL68BK H28CACSBKHC TCOLLARASSYL8GBK (2) FGIUS (2)SLGAGMKIT (2)FPH AB RFD237189		
		*** NOTES: - 1/24/19 ADDED "FPH" - DUE TO THE HEIGHT OF THE CLAMSHELL BASE AND TRANSITION COLLAR THE APPROX. HT OF THE BOTTOM RECEPTACLE WILL NEED TO BE AROUND 60"-65". APPROVAL DWG WILL VALIDATE SITELINK ALUMINUM POLE, 30' TALL, "L8G" FLUTED SHAFT WITH A PLAIN POLE CAP, (2) RECEPTACLE PROVISIONS, (2)WIREWAY DRILLINGS, SHOEBASE. HOLOPHANE BLACK SITELINK CAMDEN ARM, 48" LONG FOR A SINGLE FIXTURE, BOLT-ON WITH TRACNUTS INCLUDED. HOLOPHANE BLACK HAMILTON CAST ALUMINUM CLAMSHELL BASE, 28" DIAMETER. HOLOPHANE BLACK SITELINK TRANSITION COLLAR TO TRANSITION FROM THE POLE SHAFT TO THE CLAMSHELL BASE. HOLOPHANE BLACK GFI RECEPTACLE WITH SMALL IN-USE WEATHERPROOF COVER HOLOPHANE BLACK GASKET AND GROMMET KIT FOR ELECTRICAL WIREWAY SITELINK FLAGPOLE HOLDER FOR 1" POLE, TRACNUTS INCL. HOLOPHANE BLACK 1.25"X42" ANCHOR BOLTS INCLUDED		
	6	ESL2 P35S 40K AS BK TG 3 S AO BHDF13 200 BK		
		Esplanade Tear Drop Teardrop LED 2 Series (ESL2): ESL2, 14,900 lumens; 3 COBs, 4000K CCT, Auto-sensing voltage (120 thru 277) 50/60 HZ, Black, Teardrop glass and door, Type 3 Asymmetric Distribution, Quick Lock Stem mount, Field Adjustable Output, Boston Harbor Decorative Arm Fitter, Slips Fits 2.00 Nominal Pipe (2.38") OD, Black		



Job Name: Mascoutah Streetscape
 Quote #: 2377-17-10162-8
 Quote Label: AHD

Quoted By: Michael Cortese
 618-779-8754
 Michael.Cortese@AcuityBrands.com

Job Location: Illinois
 Issue Date: 4/1/2020
 Bid Date: 6/30/2017

Type	Qty	Catalog #	Unit \$	Ext \$
SPARE ASSEMBLY				
	1	SLA30L8GSBP01BK(2)RXXXY-MOD H28CACSBKHC TCOLLARASSYL8GBK FGIUS-SBKH AB-28-4RFD313351 SITELINK ALUMINUM POLE, 30' TALL, "L8G" FLUTED SHAFT WITH A PLAIN POLE CAP, (2) RECEPTACLE PROVISIONS, WIREWAY DRILLING, SHOEBASE. HOLOPHANE BLACK HAMILTON CAST ALUMINUM CLAMSHELL BASE, 28" DIAMETER. HOLOPHANE BLACK SITELINK TRANSITION COLLAR TO TRANSITION FROM THE POLE SHAFT TO THE CLAMSHELL BASE. HOLOPHANE BLACK GFI RECEPTACLE WITH SMALL IN-USE WEATHERPROOF COVER HOLOPHANE BLACK 1.25"X42" ANCHOR BOLTS INCLUDED		
	2	SLCAM48/1BOL68BK RFD313425 *** NOTES: - QUOTING THE ARM ONLY FROM RFD237183 FOR THE POLE ON RFD313351. SITELINK CAMDEN ARM, 48" LONG FOR A SINGLE FIXTURE, BOLT-ON WITH TRACNUTS INCLUDED. HOLOPHANE BLACK		
	2	ESL2 P35S 40K AS BK TG 3 S AO Esplanade Tear Drop Teardrop LED 2 Series (ESL2): ESL2, 14,900 lumens; 3 COBs, 4000K CCT, Auto-sensing voltage (120 thru 277) 50/60 HZ, Black, Teardrop glass and door, Type 3 Asymmetric Distribution, Quick Lock Stem mount, Field Adjustable Output, Existing Fitter (Fitter not supplied or supplied somewhere else)		

Estimated Lead Time: 90 days

Notes

- * 1. Quote number must be written on Purchase Order
- 2. Please contact Michael Cortese 618-779-8754 for questions regarding this quote.
- 3. All quotes subject to standard terms and conditions unless specifically noted.
- 4. Quote is based on quantities and types indicated. Changes in counts or types may affect prices.
- 5. Purchase orders must be faxed directly to 1-800-345-4471 or emailed to SouthCentralSalesSupport@Holophane.com. Failure to do so could result in delays in processing your order.
- 6. Customer Service Contact Information:
 Email: SouthCentralSalesSupport@Holophane.com
 New Toll Free Number: 1-855-898-8038
 Toll Free Fax: 1-800-345-4471

Terms



Job Name: Mascoutah Streetscape
Quote #: 2377-17-10162-8
Quote Label: AHD

Quoted By: Michael Cortese
618-779-8754
Michael.Cortese@AcuityBrands.com

Job Location: Illinois
Issue Date: 4/1/2020
Bid Date: 6/30/2017

HOLOPHANE: This quote is valid for 60 calendar days from date of quote. After 60 days pricing on certain product families may be adjusted based on enacted and proposed tariff increases detailed by the Office of the United States Trade Representative (USTR). Shipment lead times begin the day after the order is released and are based on working days only. Shipments are FOB Shipping Point on all orders. Holophane shall pay freight on orders of \$3,000 or more (\$750 for replacement ballast kits) to all points in the continental United States and Canada. Upon release of your order, poles and non-standard material cannot be cancelled or returned. Terms are subject to revision. Items with "Hold" status have not been allocated any labor, material, or scheduled production time. The lead time to shipment will begin when Holophane receives your clarification or approval to release your purchase order item(s) from "Hold" status. Prices in this acknowledgement are firm for release within a period of six months from the date of order. At the end of six months, Holophane, at its option, shall either increase prices by 3% or renegotiate pricing. Thereafter, escalation of 1-1/2% per three month period will be added. In the event of an extraordinary change in raw material costs, Holophane reserves the right to renegotiate pricing. Pricing will be reevaluated and confirmed upon receipt of your clarification or approval to release the purchase order item(s) from "Hold" status.